

Column1	Column2	Column3	Column4	Column5	Column6	Column7
Rye Water District--Per/Polyfluoroalkyl Substances (PFAS)		NHDES Maximum Contaminant Level (MCL) 15 PPT	12 PPT	18 PPT	11 PPT	
SystemSample(Taken@WashingtonRoadStorageTanks)	DateSampled	PFOS	PFOA	PFHxS	PFNA	AnalyticalMethod
	Aug 2017	7 ppt	4 ppt	ND	ND	PFC Isotope
	Sept 2017	5 ppt	3 ppt	ND	ND	
	Oct 2017	4 ppt	2 ppt	ND	3 ppt	
	Nov 2017	5 ppt	3 ppt	ND	ND	
	Dec 2017	ND	3 ppt	ND	ND	
	Jan 2018	ND	3 ppt	ND	ND	
	Feb 2018	ND	3 ppt	ND	ND	
	Mar 2018	ND	2 ppt	ND	ND	
	Apr 2018	5 ppt	3 ppt	ND	ND	
	May 2018	ND	4 ppt	ND	ND	
	June 2018	ND	5 ppt	ND	ND	
	July 2018	4 ppt	5 ppt	ND	ND	
	Aug 2018	ND	4 ppt	ND	ND	
	Sept 2018	ND	3 ppt	ND	ND	
	Oct 2018	ND	4 ppt	ND	ND	
	Nov 2018	4 ppt	4 ppt	ND	ND	EPA 537
	Dec 2018	ND	3 ppt	ND	ND	PFC Isotope
	Jan 2019	5 ppt	4 ppt	ND	ND	EPA 537
	Feb 2019	ND	5 ppt	ND	ND	PFC Isotope
	Mar 2019	ND	4 ppt	ND	ND	
	Apr 2019	ND	3 ppt	ND	ND	
	May 2019	ND	5 ppt	ND	ND	
	June 2019	ND	4 ppt	ND	ND	
	July 2019	ND	4 ppt	ND	ND	
	Aug 2019	4 ppt	4 ppt	ND	ND	
	Sept 2019	ND	4 ppt	ND	ND	EPA 537
	Oct 2019	2 ppt	4 ppt	ND	ND	
	Nov 2019	ND	ND	ND	ND	
	Dec 2019	3.56 ppt	4.80 ppt	ND	ND	NH-537-Isotope
	Jan 2020	3.66 ppt	5.45 ppt	ND	ND	
	Feb 2020	2.84 ppt	5.16 ppt	ND	ND	
	Mar 2020	4.52 ppt	5.21 ppt	ND	ND	
	Apr 2020	4.91 ppt	5.62 ppt	ND	ND	
	May 2020	2.90 ppt	5.40 ppt	ND	ND	
	June 2020	4.32 ppt	5.68 ppt	ND	ND	EPA 533
	July 2020	4.35 ppt	5.04 ppt	ND	ND	
	Aug 2020	4.42 ppt	5.11 ppt	ND	ND	
	Sept 2020	4.64 ppt	4.61 ppt	ND	ND	
	Oct 2020	5.31 ppt	5.31 ppt	ND	ND	
	Nov 2020	3.12 ppt	4.20 ppt	ND	ND	
	Nov 2020	4.69 ppt	5.32 ppt	ND	ND	
	Jan 2021	5.04 ppt	6.27 ppt	ND	ND	
	Apr 2021	4.35 ppt	5.71 ppt	ND	ND	
	July 2021	3.91 ppt	4.61 ppt	ND	ND	
	Oct 2021	4.63 ppt	4.70 ppt	ND	ND	
	Feb 2022	5.92 ppt	7.90 ppt	ND	ND	
	Apr 2022	4.02 ppt	5.74 ppt	ND	ND	
	Aug 2022	5.71 ppt	6.71 ppt	ND	ND	
	Nov 2022	5.23 ppt	5.24 ppt	ND	ND	
	3/29/2023	3.37	5.77	ND	ND	
	6/22/2023	4.12	5.42	ND	ND	
	7/17/2023	3.99	4.36	ND	ND	
	12/7/2023	3.53	4.53	ND	ND	
	3/6/2024	2.99	4.43	0.893	1.68	
	5/7/2024	3.93	5.18	1.28	1.64	

NHDES Regulatory Standards for 4 PFAS Maximum Contaminant Levels (MCLs) effective 09/30/19						
PFOS--15 PPT	PFOA--12 PPT	PFHxS--18 PPT	PFNA--11 PPT			
EPA Lifetime Health Advisory, dated 06/15/22						
	PFOA--0.004					
PFOS--0.02 PPT	ppt					
Acronym Key--						
PPT=parts per trillion (same as ng/L)		ND= Non Detect				